

Report No:

Revision:

Total Pages:

Date:



# Griplok<sup>®</sup> Tube Fittings

## **TECHNICAL REPORT**

## **TABLE OF CONTENTS**

- 1.0 Introduction**
- 2.0 Test Procedures and Results**
- 3.0 Validation Tests and Results**
  - 3.1 Initial Makeup Test
  - 3.2 Hydrostatic Burst Pressure Test
  - 3.3 Hydraulic Impulse Pressure Test
  - 3.4 Repeated Remake Test
  - 3.5 Tension Force Test
  - 3.6 Vibration Stress / Endurance Test
  - 3.7 Intermix Assurance Test
  - 3.8 Interchange Assurance Test
  - 3.9 Gas Pressure Leak Test
  - 3.10 Thermal Cycle, Thermal Shock Test
  - 3.11 Vacuum Test
  - 3.12 Low Temperature (Cryogenic) Helium Leak Test
- 4.0 Bibliography, Equipment, References**

## SSP INTRODUCTION

Since its inception in 1926, SSP has exhibited an expertise in the precision machining of tight tolerance, high quality fitting components. In fact, SSP's historical reputation for product quality, service and performance is recognized across the country and around the world.

In 1986, SSP relocated to its 25-acre property in Twinsburg, Ohio Southeast of Cleveland in North America's manufacturing heartland. Within its modern 165,000 square foot manufacturing facility, SSP has developed the internal ability to control its manufacturing variables as much or more than any other fittings' manufacturer. SSP designs and produces its own specialty cutting tools to proprietary standards with a 5 axis CNC tool and cutter grinder, high speed 4 axis CNC machining centers and ultra precise EDM's to allow manufacturing to the most stringent dimensional tolerances and surface finishes. Additionally, SSP's tool making capability supports an internal hot, closed-die forging operation. SSP plans, controls and performs its own metal forging operations on all elbows, tees and crosses manufactured into SSP fittings, connectors and adapters. Indeed, SSP's production capacity is among the largest single-site facilities in the entire industry with the capability to allow one-of-a kind, "specials" machining on single spindle CNC's to high volume production on multi-spindle automatics.

Furthermore, SSP's ISO9001 Quality System Certification and Registration by DNV assures conformance to the highest levels of quality. The substantial investment of time and funds to obtain and maintain such status has paid dividends for SSP and its customers in efficiencies in process and supply.

In 1993 in response to continued customer requests for an alternative product offering in the Instrumentation marketplace; strategic plans were developed to launch a division of SSP to design, manufacture and distribute American manufactured, Instrumentation quality tube fittings as a direct alternative to the registered trademark brand of Hoke Gyrolok. The recruitment of recognized Instrumentation industry experts occurred, and a specialized design and business unit team, SSP Instrumentation, was formed. Following an ISO 9001 design process pattern, the critical elements of design planning, including the detailed documentation of design inputs and outputs occurred for the development of Griplok tube fittings. Examples of such design inputs include:

- Dimensional similarity*
- Material of construction similarity*
- Installation instruction similarity*
- Operation and performance similarity*
- Brand interchangeability and intermixability*
- Corrosion resistance similarity*
- Applicable ANSI / ASME B 31.3 requirements*

To accomplish the required design plan tasks of verification and validation, a specialized Technical Center was built within SSP. In addition to the exhaustive engineering calculations for confirmation of design conformance to industry standards and other engineering developed criteria, customized NIST traceable testing equipment was procured to allow:

*Hydrostatic Proof and Burst Pressure Testing*

*Air and/or Helium Pressure Testing*

*High Vacuum Testing*

*Cyclic Vibration Testing*

*Tensile Pull Testing*

*Hydraulic Impulse Testing*

*Thermal Cycle Testing*

*Low Temperature (Cryogenic) Testing*

*High Temperature Testing*

Additional specific testing of Grielok with Hoke Gyrolok, Swagelok, and Parker CPI was undertaken to confirm design compatibility and performance similarity, as well as competitive interchangeability and intermixability.

Examples of such additional testing includes:

*Dimensional Measurement Comparison*

*Installation Make-Up Torque Comparison*

Conformance to the design engineering team's prescribed acceptance criteria allows the products' release for production and distribution to the marketplace.

## 1.0 INTRODUCTION

This document's purpose is to report, in a published format for public review, a representative sampling of the Griplik tube fitting's actual performance results from the Design Plan's Validation Tests. The performance results are measured against the Design Team's Approved Acceptance Criteria, which are based on meeting or exceeding the published and / or test-based performance of equivalent products from Hoke Gyrolok. A positive testing performance of the products in the Validation Tests was required to complete the final element of the design cycle and provide for the Design Release of the Griplik product family.

## 2.0 TEST PROCEDURES AND RESULTS

The preceding table (Table 1.0) lists the major Validation Tests that were performed, and the sections which follow describe the tests and outline specific results. All products manufactured at SSP are to approved and controlled engineering documentation, to established process and quality procedures at every stage of manufacture, with fully calibrated quality and process instrumentation, using only certified and traceable materials. Tested products were selected randomly from documented normal production runs. Before and after test samples were retained for reference. All tubing used in testing meets applicable ASTM specifications, and has approved material and chemical certifications.

All SSP tests conducted on products are with laboratory equipment and instrumentation in current calibration. Trained personnel conducted tests by following approved, written test procedures. All test results were subjected to thorough engineering review and approval before internal publication.

In every case all Griplik test results met or exceeded the established Design Team's Acceptance Criteria for these products. As such, they also met or exceeded equivalent major competitive product performance, as measured in test data and / or reported in publications.

## Section 3.0: Validation Tests and Results

### Section 3.1: Initial Makeup Test

**Purpose:** Test determines if the tube and fitting assembly has comparable levels of assembly torque to that of Hoke Gyrolok, and achieves proper fitting makeup.

NOTE: Instrumentation Tube Fittings, due to the variances of tubing hardness and outside / inside diameters, require a certain geometric rotation of the tubing nut for proper makeup.

Assembly torque requirements vary per application and the level of torque is a general consideration, not a specification, for proper makeup.



**Equipment & Configuration:**

Saw, tube deburring tool, vice and torque wrench. See Figures 3.1.1 - 2, Initial Makeup

**Figures 3.1.1 - 2, Initial Makeup: Torque Measurement and Fitting Assembly**

**Test Procedure:** The fitting and tube are assembled per published standard fitting makeup instructions. Torque, in inch-pounds (or foot-pounds), vs. nut tightening rotation is recorded in ¼ turn increments.

**ACCEPTANCE CRITERIA:**

Fitting is to achieve proper makeup, with average assembly torque being equal to or less than Hoke Gyrolok average results, and individual results being less than the Hoke Gyrolok average plus 3. See Example Acceptance Criteria in Table 3.1.1 below.

Tubing / Fitting			Acceptance Criteria					Ave + 3σ
			Torque, in-lb					
Size	Wall	W.P.	Revolutions					
#	in.	psig	0.25	.50	0.75	1.00	1.25	1.25
8	0.035	2,450	38	105	172	216	249	387
	0.083	6,250	37	111	280	385	493	781

**Table 3.1.1, Example Initial Makeup Torque Acceptance Criteria**

**Test Results:** Example results are shown in Table 3.1.2 below.

### Results: Initial Makeup Torque Test

Sample No.	Initial Makeup Torque, in-lb												Test
	Size #	8	X	0.035	Wall Tubing		Size #	8	X	0.083	Wall Tubing		
	Revolutions					Pass / Fail	Revolutions					Pass / Fail	
	0.25	0.50	0.75	1.00	1.25	P / F	0.25	0.50	0.75	1.00	1.25	P / F	
1	25	70	100	140	155	P	30	125	200	250	340	P	Bite
2	30	70	125	150	165	P	30	105	170	230	325	P	
3	40	70	90	125	130	P	25	110	190	240	355	P	
4	50	90	150	175	195	P	30	130	200	270	360	P	
1	40	95	135	180	190	P	30	120	245	340	450	P	Tension
2	40	70	100	155	160	P	30	105	240	325	415	P	
3	40	70	120	155	160	P	30	110	200	245	310	P	
4	30	65	100	150	170	P	30	125	190	290	415	P	
5	30	75	150	200	220	P	30	120	190	300	410	P	
1	30	75	135	160	175	P	50	140	205	250	330	P	Gas Leak
2	25	85	140	175	200	P	50	110	180	220	270	P	
3	30	90	115	160	180	P	55	125	220	275	365	P	
4	25	75	115	170	190	P	40	120	185	230	290	P	
5	35	90	125	155	175	P	45	145	210	300	385	P	
6	50	70	85	120	145	P	50	120	190	210	290	P	
7	45	80	115	170	185	P	30	100	150	210	255	P	
8	25	60	90	120	175	P	30	100	180	220	275	P	
9	30	65	85	110	140	P	40	110	195	230	295	P	
10	35	65	90	125	130	P	45	110	170	210	270	P	
11	30	70	90	110	165	P	30	100	180	220	280	P	
12	40	90	125	160	180	P	55	165	260	330	390	P	
1	30	75	105	115	155	P	60	110	210	245	330	P	Thermal Cycle
2	35	80	110	160	225	P	70	145	200	230	335	P	
3	30	95	160	200	205	P	55	125	210	240	365	P	
4	30	75	110	125	155	P	25	145	210	280	395	P	
5	30	65	105	150	190	P	40	110	150	195	295	P	
1	35	90	125	160	190	P	40	120	205	310	400	P	Remake
2	25	70	100	125	145	P	40	110	140	220	280	P	
3	25	50	95	130	165	P	40	110	170	230	360	P	
4	20	70	120	150	195	P	30	125	220	285	350	P	
5	30	75	110	135	160	P	50	115	160	205	285	P	
6	25	60	100	150	160	P	30	105	165	225	295	P	

**Table 3.1.2, Example Initial Makeup Torque Results**

## CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria.

## Section 3.2: Hydrostatic Burst Pressure Test

**Purpose:** Test determines if the tube fitting assembly has adequate pressure-retaining capability, based on the ANSI / ASME B 31.3 maximum allowable working pressure of the tubing.

**Equipment & Configuration:** Two fittings are tested at a time – one on each end of a 4 ½” long piece of tubing, per Initial Makeup Test (see Section 3). Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figures 3.2.1 – 3.



Figure 3.2.1 - 2, Burst Test Configuration




Figure 3.2.3, Burst Test Specimen

**Test Procedure:** The tube fitting assembly is hydrostatically pressurized in regular pressure increments which increase until tube burst is attained. The digitally displayed maximum pressure, in PSIG, - at which the tubing bursts or tubing pushes out of the fitting - is recorded.

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain a hydrostatic pressure, without observed leakage, exceeding a minimum of 4 times the ANSI / ASME maximum allowable working pressure of the tubing. Failure is to be by tubing burst, not by tube push out from fitting.



**Test Results:** Example results are shown in Table 3.2.0 below.

**Results: Burst Test (Sample - Tube ends: A, B)**

Test	Sample No.		Tubing / Fitting		Acceptance Criteria		Burst Test		
	A	B	Size	Wall	W.P.	Burst = 4 x W.P.	Actual Burst	Fail Type	Pass / Fail
	#	#	#	in.	psig	psig	psig	n/a	P / F
Impulse	1	2	8	0.035	2,450	9,800	12,290	Tube	P
	3	4					12,230	Tube	P
	5	6					12,240	Tube	P
	7	8					12,300	Tube	P
	9	10					10,350	Tube	P
	11	12					10,400	Tube	P
	1	2	8	0.083	6,250	25,000	27,940	Tube	P
	3	4					27,970	Tube	P
	5	6					27,690	Tube	P
	7	8					28,080	Tube	P
	9	10					28,100	Tube	P
	11	12					27,940	Tube	P
Remake	1	2	8	0.035	2,450	9,800	10,350	Tube	P
	3	4					12,330	Tube	P
	5	6					12,260	Tube	P
	1	2	8	0.083	6,250	25,000	27,940	Tube	P
	3	4					28,270	Tube	P
	5	6					28,050	Tube	P
Vibration	1		8	0.035	2,450	9,800	12,190	Tube	P
	2						12,340	Tube	P
	3						12,190	Tube	P
	4						12,190	Tube	P

**Table 3.2.0, Example Burst Test Results**

## CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. All Griplik tube fittings sustained the required maximum allowable working pressure without leakage, and held leak free to tubing burst, without exhibiting tube push out from the fitting.

## Section 3.2: Hydrostatic Impulse Test

**Purpose:** Test determines if the tube fitting assembly can sustain extended pressure cycling without leakage.

**Equipment & Configuration:** For each stand manifold position, two fittings are tested at a time – one on each end of a test tube piece. Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figures 3.3.1 – 2.



Figure 3.3.1 - 2, Hydraulic Impulse Test Stand and Fixture

**Test Procedure:** The tube fitting assembly is pressurized with hydraulic test oil in a manifold with up to 24 fittings. The hydraulic fluid temperature and the pressure cycle envelope conform to MIL-H-24135 test specification. Peak test pressure is 5,250 PSIG, sustained at 30 cycles/minute. Test oil temperature is maintained between 120°F-125°F. Following the Hydraulic Impulse Test, samples are also subjected to Burst Test.

### ACCEPTANCE CRITERIA:

**Hydraulic Impulse Test:** The tube fitting assembly is to sustain pressure cycling without observed leakage for 150,000 test cycles.

**Burst Test:** The tube fitting assembly is to sustain a hydrostatic pressure, without observed leakage, exceeding a minimum of 4 times the ANSI / ASME maximum allowable working pressure of the tubing. Failure is to be by tubing burst, not by tube push out from fitting.

**Test Results:** Example results are shown in Table 3.3.0 below.

**Results: Impulse Test, followed by Burst Test:**

Test	Sample No.		Tubing / Fitting		Acceptance Criteria			Impulse Test		
	A	B	Size	Wall	Impulse Cycles	Test Press.	Leak	Cycles without Failure	Leak	Pass / Fail
	#	#	#	in.	cycles	psig	Leak / None	Cycles x 10 <sup>3</sup>	Leak / None	P / F
Impulse	1	2	8	0.035	150,000	5,250	None	150	None	P
	3	4						150	None	P
	5	6						150	None	P
	7	8						150	None	P
	9	10						150	None	P
	11	12						150	None	P
	1	2	8	0.083	150,000	5,250	None	150	None	P
	3	4						150	None	P
	5	6						150	None	P
	7	8						150	None	P
	9	10						150	None	P
	11	12						150	None	P

Test	Sample No.		Tubing / Fitting		Acceptance Criteria		Burst Test		
	A	B	Size	Wall	W.P.	Burst = 4 x W.P.	Burst Actual	Fail Type	Pass / Fail
	#	#	#	in.	psig	psig	psig	n/a	P / F
Impulse	1	2	8	0.035	2,450	9,800	12,290	Tube	P
	3	4					12,230	Tube	P
	5	6					12,240	Tube	P
	7	8					12,300	Tube	P
	9	10					10,350	Tube	P
	11	12					10,400	Tube	P
	1	2	8	0.065	6,250	25,000	27,940	Tube	P
	3	4					27,970	Tube	P
	5	6					27,690	Tube	P
	7	8					28,080	Tube	P
	9	10					28,100	Tube	P
	11	12					27,940	Tube	P

NOTE: A.C. = Acceptance Criteria

**Table 3.3.0, Example Hydraulic Impulse and Burst Test Results**

**CONCLUSIONS:**

All Griplik assemblies met or exceeded the approved Acceptance Criteria. No leakage or rupture of a Griplik tube fitting assembly was observed beneath 4X working pressure.

## Section 3.4: Repeated Remake Test

**Purpose:** Test determines capability of the tube fitting assembly to successfully seal after repeated assembly and disassembly of a made-up tube assembly with a mating fitting. This test simulates the normal use condition where fittings are repeatedly disassembled from fittings for fluid system service or maintenance, and reassembled with additional tightening.

**Equipment & Configuration:** Two fittings are tested at a time – one on each end of a 4 ½” long piece of tube, per Initial Makeup Test (see Section 3). Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figure 3.4.1, Repeated Remake Test



**Figure 3.4.1, Repeated Remake Test (Size 8 Griplok)**

**Test Procedure:** To simulate repeated remake conditions, the tube fitting is disassembled and assembled (tightening from the preceding installation position an additional 1/12 turn – or 30 each time) at each reassembly, for five successive times. This is followed by air pressure testing to the maximum recommended working pressure of the tubing, under water to observe leakage. After each disassembly of the tube fitting assembly it is examined for absence of the following Remake Failure Criteria:

Tube Sticking, Body Swelling, Nut Sticking, Thread Galling, Ferrule Set,  
Ferrule Galling, Body Dent ing, Excessive Torque, Tube push out or burst.

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain an air booster test pressure, PSIG, of the ANSI / ASME maximum allowable working pressure of the tubing, up to a maximum pressure of 10,000 PSIG. Failure is either any observed air leakage bubble, or the presence of any of the above Remake Failure Criteria.

**Test Results:** Example results are shown in Table 3.4.0 below.

Tubing Size #:		8			
Tubing Wall:		0.035 in.		0.083 in.	
Gas Leak Test Press.		2,450 psig		6,250 psig	
Acceptance Criteria:		None Leak / None		None Leak / None	
Sample	Remake	Gas Leak Test		Gas Leak Test	
#	#	Leak / None	P / F	Leak / None	P / F
1	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P
2	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P
3	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P
4	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P
5	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P
6	1	None	P	None	P
	2	None	P	None	P
	3	None	P	None	P
	4	None	P	None	P
	5	None	P	None	P

**Table 3.4.0, Example Repeated Remake Test Results**

## CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. No leakage or Remake failures were observed in any Griplik tube fitting assemblies.

## Section 3.5: Tension Test

**Purpose:** Test determines if the tube fitting assembly has the capability to sustain axial forces equivalent to the hydrostatic end force caused by approaching four times tubing working pressure. This test simulates end loading of straight, stiff, tube assemblies subjected to large end loads, as occur with structural deflection and thermal expansions.

**EQUIPMENT & CONFIGURATION:** One fitting is assembled on the end of a test tube, per Initial Makeup Test (see Section 3). Tensile loads are applied via a Tensile Test machine. Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figure 3.5.1.




Figure 3.5.1, Tension Test Configuration.

**Test Procedure:** The tube fitting assembly is axially loaded in tension, and increasing loads are applied until tubing pull out is observed. The maximum load sustained by the fitting, in pounds, is recorded by digital force instrumentation.

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain an end force approaching that equivalent to the end force produced by 4 times the ANSI / ASME maximum allowable working pressure of the tubing. Failure is a pull out force less than this equivalent end load.

**Test Results:** Example results are shown in Table 3.5.0 below.

### Results: Tension Test

Sample No.	Tubing / Fitting		Acceptance Criteria		Tension Test				
	Size	Wall	W.P.	Burst = 4 x W.P. (Basis of Pullout Force)	Tubing O.D.	Pullout Force (Based on 4 x W.P.)	Actual Pullout Force	Fail Type	Pass / Fail
#	#	in.	psig	psig	in.	lb	lb	#	P / F
1	8	0.028	2,450	9,800	0.5000	1,924	2,734	1	P
2					0.5000	1,924	2,622	1	P
3					0.5000	1,924	2,790	1	P
4					0.5000	1,924	2,808	1	P
5					0.5000	1,924	2,780	1	P
1		0.083	6,250	25,000	0.4990	4,889	5,694	1	P
2					0.4990	4,889	5,960	1	P
3					0.4990	4,889	5,938	1	P
4					0.4990	4,889	5,780	1	P
5					0.4990	4,889	5,660	1	P

NOTE: A.C. = Acceptance Criteria

#### FAIL TYPE #:

- \*1 Pullout
- \*2 Broke in Tension at the rear ferrule.
- \*3 Tube broke in Tension at mid-length.

### Table 3.5.0, Example Tension Test Results

#### CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. Observed pull out forces generally exceeded the equivalent of four times tubing working pressure for all Griplik tube fitting assemblies.

## Section 3.6: Vibration Test

**Purpose:** Test determines if the tube fitting assembly has high resistance to vibration based fatigue when simultaneously exposed to 1.6 times tubing maximum allowable working pressure, based on the ANSI / ASME B 31.3 maximum allowable working pressure of the tubing.

**EQUIPMENT & CONFIGURATION:** One fitting is tested at a time in each station of the stand. The fitting is assembled to one end of a test tube, made up per Initial Makeup Test (see Section 3). A small format strain gage is mounted axially on the tube next to the fitting nut, and the gage is read by peak stress detecting strain gage instrumentation. A motor coaxial to the fitting axis turns a faceplate containing a spherical bearing that is radially offset to produce cyclic strain on the tested tube fitting assembly.

Samples of tubing with the minimum recommended wall (worst case condition) are used for each tested product configuration. See Figures 3.6.1 - 2.




Figure 3.6.1 - 2, Vibration Test Stand and Test Configuration

**Test Procedure:** The motor faceplate is adjusted to produce a maximum stress adjacent the tube fitting nut equal to 60% of the tubing yield stress (YS), in KSI, as digitally indicated on the strain gage instrumentation. The tube fitting assembly is hydrostatically pressurized to 1.6 times the tubing maximum allowable working pressure and isolated from the pump by a valve. A digital counter counts revolutions of the motor faceplate (equal to the number of complete stress cycles from maximum tensile to maximum compressive stress of 60% of YS). A pressure switch stops the test on any loss of pressure during the test.

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain a combination of hydrostatic pressure equal to 1.6 times the ANSI / ASME maximum allowable working pressure of the tubing, and 10 million stress cycles. Failure is any loss of pressure in the tube fitting assembly.



**Test Results:** Example results are shown in Table 3.6.0 below.

### Configuration: Vibration Test

Strain Gage Data:		
Item	Value	Unit
Lot number:	R-A63BD06	n/a
Stock number:	EA-06-062EN-350	n/a
Gage factor:	2.08±0.5% @ 24° C	dmls
Gage Excitation Voltage:	5	V
Peak Stress value:	12,000	psi
Modulus of Elasticity:	30,000,000	psi
Strain setting:	400	µε

### Results: Vibration Test

Test	Sample No.	Tubing / Fitting		Acceptance Criteria			Vibration Test		
		Size	Wall	Vibr. Cycles	Test Press.	Leak	Cycles without Failure	Leak	Pass / Fail
		#	in.	Cycles	psig	Leak / None	Cycles x 10 <sup>6</sup>	Leak / None	Pass / Fail
Vibration	1	8	0.035	10,000,000	3,920	None	10	None	P
	2						10	None	P
	3						10	None	P
	4						10	None	P

### Results: Burst Test after Vibration Test

Test	Sample No.	Tubing / Fitting				Burst Test		
		Size	Wall	W.P.	Burst A.C. = 4 x W.P.	Actual Burst	Fail Type	Pass / Fail
		#	in.	psig	psig	psig	n/a	Pass / Fail
Vibration	1	8	0.035	2,450	9,800	12,190	Tube	P
	2					12,340	Tube	P
	3					12,190	Tube	P
	4					12,190	Tube	P

NOTE: A.C. = Acceptance Criteria

## Table 3.6.0, Example Vibration Test Results

### CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. No observed leaks or loss of pressure occurred in any Griplik tube fitting assemblies.

## Section 3.7: Intermix Test

**Purpose:** Test determines if all combinations of tube fitting components (nut, back ferrule, front ferrule and fitting body) of Griplok and Hoke Gyrolok can be intermixed in a tube fitting assembly. The resulting assembly must have both adequate gas and liquid pressure-retaining capability, based on ANSI / ASME B 31.3 maximum allowable working pressure of the tubing.

This test simulates the random intermixing of inventoried Griplok and Hoke Gyrolok fitting components in the field to make up tube fitting assemblies.

**EQUIPMENT & CONFIGURATION:** Two fittings of a given combination of fitting components are tested at a time – one on each end of a 4 ½” long piece of tube, per Initial Makeup Test (see Section 3). Samples with maximum recommended wall tubing (worst case condition) are used for each tested product configuration. See Figure 3.7.1, and Table 3.7.1.



Figure 3.7.1, Intermix Test Configuration.

Combinations							
Components	1	2	3	4	5	6	7
Body	Gyrolok	Gyrolok	Gyrolok	Griplok	Gyrolok	Griplok	Gyrolok
Front Ferrule	Gyrolok	Gyrolok	Griplok	Gyrolok	Gyrolok	Griplok	Griplok
Back Ferrule	Gyrolok	Griplok	Gyrolok	Gyrolok	Griplok	Gyrolok	Griplok
Nut	Griplok	Gyrolok	Gyrolok	Gyrolok	Griplok	Gyrolok	Griplok

Combinations							
Components	8	9	10	11	12	13	14
Body	Griplok	Griplok	Griplok	Gyrolok	Griplok	Gyrolok	Griplok
Front Ferrule	Griplok	Griplok	Gyrolok	Griplok	Gyrolok	Griplok	Gyrolok
Back Ferrule	Griplok	Gyrolok	Griplok	Griplok	Gyrolok	Gyrolok	Griplok
Nut	Gyrolok	Griplok	Griplok	Gyrolok	Griplok	Griplok	Gyrolok

Table 3.7.1: Intermix Test Combinations

**Test Procedure:** The tube fitting assembly is subjected to the Gas Leak Test (see Section 3.9), and then the Burst Test (see Section 3.2).

## ACCEPTANCE CRITERIA:

**Gas Leak Test:** The tube fitting assembly is to sustain an air booster test pressure, PSIG, of the ANSI / ASME maximum allowable working pressure of the tubing, up to a maximum pressure of 10,000 PSIG. Failure is any observed air leakage bubble.

Report No:

Revision:

Total Pages:

Date:

**Burst Test:** The tube fitting assembly is to sustain a hydrostatic pressure, without observed leakage, exceeding a minimum of 4 times the ANSI / ASME maximum allowable working pressure of the tubing. Failure is to be by tubing burst, not by tube push out from fitting.

**Test Results:** Example results are shown in Table 3.7.2 below.

Sample #	Tubing / Fitting		Acceptance Criteria				#	Gas Leak Test		Burst Test		
	Size No.	Wall	W.P.	Burst = 4 x W.P.	Gas Leak Press.	Leak		Leak / None	Pass / Fail	Actual Burst	Fail Type	Pass / Fail
#	#	in.	psig	psig	psig	Leak / None	#	Leak / None	P / F	psig	n/a	P / F
1	8	0.083	6,250	25,000	6,250	None	1	None	P	27,640	Tube	P
2							None	P				
3							2	None	P	27,460	Tube	P
4								None	P			
5							3	None	P	27,860	Tube	P
6								None	P			
7							4	None	P	27,970	Tube	P
8								None	P			
9							5	None	P	28,030	Tube	P
10								None	P			
11							6	None	P	28,180	Tube	P
12								None	P			
13							7	None	P	27,910	Tube	P
14								None	P			
15							8	None	P	27,840	Tube	P
16								None	P			
17							9	None	P	27,460	Tube	P
18								None	P			
19							10	None	P	27,770	Tube	P
20								None	P			
21							11	None	P	28,510	Tube	P
22								None	P			
23							12	None	P	28,310	Tube	P
24								None	P			
25							13	None	P	28,050	Tube	P
26								None	P			
27							14	None	P	28,180	Tube	P
28								None	P			

**Table 3.7.2, Example Intermix Test Results**

## CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. All Griplik tube fittings sustained the required maximum allowable working pressure without leakage, and held leak free to tubing burst without exhibiting tube push out from the fitting.

## Section 3.8: Interchange Test

**Purpose:** Test determines if all combinations of both a tube fitting body and a tubing assembly (tube, nut, back ferrule, and front ferrule, assembled together per standard assembly instructions) of Griplik and a competitive fitting brand can be Interchanged in a complete tube fitting assembly. The resulting assembly must have both adequate gas and liquid pressure-retaining capability, based on ANSI / ASME B 31.3 maximum allowable working pressure of the tubing.

This test simulates the interchange of fitting bodies with already made up tube assemblies in the field, for components from Griplik, Swagelok, Parker CPI or Hoke Gyrolok fittings.

**EQUIPMENT & CONFIGURATION:** Two fittings of a given combination of fitting components are tested at a time – one on each end of a 4 ½" long test tube, per Initial Makeup Test (see Section 3). Samples with maximum recommended wall tubing (worst case condition) are used for each tested product configuration. See Figures 3.8.1 – 2.




Figure 3.8.1, Interchange Test Combinations



Figure 3.8.2, Interchange Test Fittings and Components

**Test Procedure:** The tube fitting assembly is subjected to the Gas Leak Test (see Section 3.9), and then the Burst Test (see Section 3.2).

## ACCEPTANCE CRITERIA:

**Gas Leak Test:** The tube fitting assembly is to sustain an air booster test pressure, PSIG, of the ANSI / ASME maximum allowable working pressure of the tubing, up to a maximum pressure of 10,000 PSIG. Failure is any observed air leakage bubble.

**Burst Test:** The tube fitting assembly is to sustain a hydrostatic pressure, without observed leakage, exceeding a minimum of 4 times the ANSI / ASME maximum allowable working pressure of the tubing. Failure is to be by tubing burst, not by tube push out from fitting.

**Test Results:** Example results are shown in Table 3.8.0 below.

### Results: Interchange Test

Sample	Tubing / Fitting		Acceptance Criteria				Combinations:		Gas Leak Test		Burst Test		
	Size No.	Wall	W.P.	Burst = 4 x W.P.	Gas Leak Press.	Leak	Nut & Ferrule (s)	Body	Leak	Pass Fail	Actual Burst	Fail Type	Pass / Fail
#	#	in.	psig	psig	psig	Leak / None	Name	Name	Leak / None	P / F	psig	n/a	P / F
1	8	0.035	2,450	9,800	2,450		Swagelok	Griplok	None	P	12,260	Tube	P
2									None	P		Tube	P
3							Gyrolok	Griplok	None	P	10,430	Tube	P
4									None	P		Tube	P
5							CPI	Griplok	None	P	12,350	Tube	P
6									None	P		Tube	P
7							Griplok	CPI	None	P	12,370	Tube	P
8									None	P		Tube	P
9							Griplok	Swagelok	None	P	12,350	Tube	P
10									None	P		Tube	P
11							Griplok	Gyrolok	None	P	12,330	Tube	P
12									None	P		Tube	P
1	8	0.083	6,250	25,000	6,250		Swagelok	Griplok	None	P	27,550	Tube	P
2									None	P		Tube	P
3							Gyrolok	Griplok	None	P	27,850	Tube	P
4									None	P		Tube	P
5							CPI	Griplok	None	P	27,600	Tube	P
6									None	P		Tube	P
7							Griplok	CPI	None	P	27,550	Tube	P
8									None	P		Tube	P
9							Griplok	Swagelok	None	P	27,530	Tube	P
10									None	P		Tube	P
11							Griplok	Gyrolok	None	P	27,640	Tube	P
12									None	P		Tube	P

**Table 3.8.0 Example Interchange Test Results**

### CONCLUSIONS:

All interchanged Griplok assemblies met or exceeded the approved Acceptance Criteria. All Griplok tube fittings sustained the required maximum allowable working pressure without leakage, and held leak free to tubing burst without exhibiting tube push out from the fitting.

## Section 3.9: Gas Leak Test

**Purpose:** Test determines if the tube fitting assembly has adequate gas pressure-retaining capability, based on the ANSI / ASME B 31.3 maximum allowable working pressure of the tubing.

**EQUIPMENT & CONFIGURATION:** Two fittings are tested at a time – one on each end of a 4 ½” long test tube, per Initial Makeup Test (see Section 3). Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figure 3.9.1 - 2, Gas Leak Test Configuration.



Figure 3.9.1 - 2, Gas Leak Test Configuration.

**Test Procedure:** The tube fitting assembly is pressurized, under water, with air in regular pressure increments to the lower of either the maximum allowable working pressure of the tubing or 10,000 PSIG, is attained. This pressure is held for a minimum of five minutes. The digitally displayed maximum pressure, in PSIG, is recorded

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain an air booster test pressure, PSIG, of the ANSI / ASME maximum allowable working pressure of the tubing, up to a maximum pressure of 10,000 PSIG. Failure is any observed air leakage bubble.

**Test Results:** Example results are shown in Table 3.9.0 below.

### Results: Gas Leak Test

Test	Sample No.		Tubing / Fitting		Acceptance Criteria				Gas Leak Test	
	A	B	Size	Wall	W.P.	Burst = 4 x W.P.	Test Press.	Leak	A.C. Leak	Pass / Fail
	#	#	#	in.	psig	psig	psig	Leak / None	Leak / None	P / F
Gas Leak	1	2	8	0.035	2,450	9,800	2,450	None	None	P
	3	4							None	P
	5	6							None	P
	7	8							None	P
	9	10							None	P
	11	12							None	P
	1	2	8	0.083	6,250	25,000	6,250	None	None	P
	3	4							None	P
	5	6							None	P
	7	8							None	P
	9	10							None	P
	11	12							None	P

NOTE: A.C. = Acceptance Criteria

### Table 3.9.0 Example Gas Leak Test Results

#### CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. No Griplik tube fitting assemblies developed observable Gas Leakage.

## Section 3.10: Thermal Cycle, Thermal Shock Test

**Purpose:** Test determines if the tube fitting assembly has the capability to sustain substantial and rapid temperature cycling while maintaining vacuum and pressure retention capabilities.

**EQUIPMENT & CONFIGURATION:** One fitting is tested at a time on the end of a test tube, assembled per Initial Makeup Test (see Section 3). Both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figure 3.10.1 - 2, Thermal Cycle, Thermal Shock Test Configuration.



Figure 3.10.1 - 2, Thermal Cycle, Thermal Shock Test Configuration.

**Test Procedure:** A thermocouple is directly attached to the fitting to ensure accurate achievement of test temperature. The tube fitting assembly is pressurized with air to 1,000 PSIG, and simultaneously heated in a tubular furnace to 1,000 F (538 C). The digitally displayed maximum pressure, in PSIG, and temperature is recorded. On reaching both pressure and temperature the tube fitting assembly is removed and rapidly cooled to ambient temperature. This cycle is repeated three times.

The above thermal cycling is followed by a vacuum test whereby a high vacuum is drawn on the inside of the fitting by Vacuum Test Equipment, helium gas is sprayed over the outside of the fitting and a leakage rate is recorded.

### ACCEPTANCE CRITERIA:

The tube fitting assembly is to sustain the above thermal cycling under air pressure, and after quenching to room temperature not exhibit any detectable leakage when immersed in water. Additionally, when subsequently subjected to the vacuum test, the fitting must not exhibit a helium vacuum test leak rate in excess of  $< 4 \times 10^{-9}$  mbar l/s.



**Test Results:** Example results are shown in Table 3.10.0 below.

### Results: Thermal Cycle, Vacuum Tests

Sample	Tubing		Acceptance Criteria			Cycle No.	Vacuum Test	
	Size No.	Wall	Temperature	Test Press.	Leak Rate		Leak Rate	Pass / Fail
#	in.	in.	°F	psig	atm cc/s	#	atm cc/s	P / F
1	8	0.035	Amb. to 1,000	1,000	1.00E-08	1	0.3E-09	P
						2		
						3		
2						1	0.2E-09	P
						2		
						3		
3						1	0.1E-09	P
						2		
						3		
4						1	0.7E-09	P
		2						
		3						
5		1	0.1E-09	P				
		2						
		3						
1	0.083	Amb. to 1,000	1,000	1.00E-08	1	0.1E-09	P	
					2			
					3			
2					1	0.1E-09	P	
					2			
					3			
3					1	1.3E-09	P	
					2			
					3			
4					1	0.8E-08	P	
		2						
		3						
5		1	0.9E-08	P				
		2						
		3						

NOTE: A.C. = Acceptance Criteria

### Table 3.10.0 Example Thermal Cycle Test Results

#### CONCLUSIONS:

All Griplik assemblies met or exceeded the approved Acceptance Criteria. Observed leak rates of tested Griplik tube fitting assemblies performed consistently better than the required Acceptance Criteria, and published competitive results.

## Section 3.11: Vacuum Test

**Purpose:** Test determines if the tube fitting assembly has the capability to seal at high vacuums, with ultra low leakage rates.

**EQUIPMENT & CONFIGURATION:** One fitting is tested at a time on the end of a piece of tubing, assembled per Initial Makeup Test (see Section 3). Samples of both minimum and maximum recommended wall tubing (worst case conditions) are used for each tested product configuration. See Figure 3.11.1 - 2, Vacuum Test Configuration.



Figure 3.11.1 - 2, Vacuum Test Configuration

The Leak Rate Sensitivity of the Veeco MS-40 Helium Leak Detection Test Equipment is  $4.0 \times 10^{-11}$  mbar l/s. Griplok fittings have been tested and shown results in the 10-11 mbar l/s range.


Test Port pressure is displayed in units of milli-Torr. The vacuum levels developed during testing are as low as 4 mT - 9mT. This equates to an absolute pressure of .0000744 - 0.000174 PSIA.

**Test Procedure:** The internal volume of the tube fitting assembly is evacuated to a vacuum of 4 mT – 9 mT (milli-Torr). The digitally displayed vacuum pressure, in mT, is recorded. On achieving full vacuum pressure, helium gas is sprayed around the outside of the fitting, and the leakage rate is recorded.

**ACCEPTANCE CRITERIA:**

The tube fitting assembly is to sustain the above vacuum pressure, and not exhibit a helium test leak rate in excess of  $< 4 \times 10^{-9}$  mbar l/s.

What this ultra low level Leak Rate means in practical terms is shown in the following table, which gives the time (in months, years) it would take for the listed Leak Rates to fill one cubic inch of volume with air to atmospheric pressure at ambient temperature:



**1 Cubic Inch**

<u>Fitting Leak Rate</u>	<u>Time for Fitting Leak to fill 1.0 in<sup>3</sup> @ 1 Atmosphere Pressure</u>
$1.0 \times 10^{-6}$ mbar l/s	6.3 months (192 days)
$1.0 \times 10^{-9}$ mbar l/s	527 years
$1.0 \times 10^{-11}$ mbar l/s	52,655 years

**CONCLUSIONS:**

All Griplik assemblies met or exceeded the approved Acceptance Criteria. Observed leak rates of tested Griplik tube fitting assemblies performed consistently better than the required Acceptance Criteria, and published competitive results.

## Section 3.12: Low Temperature (Cryogenic) Helium Leak Test

**Purpose:** Test determines if the tube fitting assembly has the capability to seal in low temperature (cryogenic) applications with ultra low leakage rates.

**EQUIPMENT & CONFIGURATION:** One fitting is tested at a time on the end of a test tube, assembled per Initial Makeup Test (see Section 3). Samples of tubing with the minimum recommended wall thickness (worst case condition) are used for each tested product configuration. See Figure 3.12.1, Low Temperature Helium Leak Test Configuration.



**Figure 3.12.1, Low Temperature Helium Leak Test Configuration.**

The Leak Rate Sensitivity of the Veeco MS-40 Helium Leak Detection Test Equipment is  $4.0 \times 10^{-11}$  std cc/sec. Griplik tube fittings have been tested and shown results in the 10-11 mbar l/s range.

Test Port pressure is displayed in units of milli-Torr. The vacuum levels developed during testing are as low as 4 mT - 9mT. This equates to an absolute pressure of .0000744 - 0.000174 PSIA.

**Test Procedure:** The tube fitting assembly is immersed in a liquid nitrogen bath, -320 F (-196 C), and the internal volume of the tube fitting assembly is evacuated to a vacuum of 4 mT – 9 mT (milli-Torr). The digitally displayed Low Temperature Helium Leak pressure, in mT, is recorded. Helium is also cooled to the liquid nitrogen temperature before being sprayed on the cold fitting exterior. On achieving full Low Temperature Helium Leak pressure, -320 F (-196 C) helium gas is sprayed around the outside of the fitting, and the leakage rate is recorded.





Figure 3.12.2, Low Temperature Helium Leak Test Sequence.

**ACCEPTANCE CRITERIA:**

The tube fitting assembly is to sustain the above low temperature, and not exhibit a helium test leak rate in excess of  $< 4 \times 10^{-9}$  mbar l/s.

What this ultra low level Leak Rate means in practical terms is shown in the following table, which gives the time (in months, years) it would for the listed Leak Rates to fill one cubic inch of volume with air to atmospheric pressure at ambient temperature:

**1 Cubic Inch**



<u>Fitting Leak Rate</u>	<u>Time for Fitting Leak to fill 1.0 in<sup>3</sup> @ 1 Atmosphere Pressure</u>
$1.0 \times 10^{-6}$ mbar l/s	6.3 months (192 days)
$1.0 \times 10^{-9}$ mbar l/s	527 years
$1.0 \times 10^{-11}$ mbar l/s	52,655 years

**CONCLUSIONS:**

All Griplik assemblies met or exceeded the approved Acceptance Criteria. Observed leak rates of tested Griplik tube fitting assemblies performed consistently better than the required Acceptance Criteria, and published competitive results.

## Section 14: Bibliography, Equipment, References

Table 4.1: ASTM Material Standards

Standard	Material Shape	Description
A 182	Forged Fittings, Parts	Standard Specification for Forged or Rolled Alloy-Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service
A 276	Bars	Standard Specification for Stainless Steel Bars and Shapes
A 479	Bar, Shapes	Standard Specification for Stainless Steel Bars and Shapes for Use in Boilers and Other Pressure Vessels
B 16	Bar, Shapes	Standard Specification for Free-Cutting Brass Rod, Bar and Shapes for Use in Screw Machines
B 124	Bar, Shapes	Standard Specification for Copper and Copper Alloy Forging Rod, Bar, and Shapes
B 453	Bar, Shapes	Standard Specification for Copper-Zinc-Lead Alloy (Leaded-Brass) Rod
A 179	Tube	Standard Specification for Seamless Cold-Drawn Low-Carbon Steel Heat-Exchanger and Condenser Tubes
A 213	Tube	Standard Specification for Seamless Ferritic and Austenitic Alloy-Steel Boiler, Superheater, and Heat-Exchanger Tubes
A 249	Tube	Standard Specification for Welded Austenitic Steel Boiler, Superheater, Heat-Exchanger, and Condenser Tubes
A 269	Tubing	Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service
B 68	Tube	Standard Specification for Copper Tube, Bright Annealed
B 75	Tube	Standard Specification for Seamless Copper Tube
B 88	Tube	Standard Specification for Seamless Copper Water Tube

Table 4.2: Applicable Codes and Standards

Section	Test Description
ANSI / ASME B 31.1	Power Piping Code
ANSI / ASME B 31.3	Process Piping Code
ANSI / ASME BPV Section VIII	Boiler & Pressure Vessel Code
ISO 7257	Aircraft - Hydraulic tubing joints and fittings - Rotary flexure test

Table 4.3: Validation Test Equipment

Section	Test Description	Test Equipment Description
3.1	Initial Makeup Test	1016702 Torque Wrench
3.2	Hydrostatic Burst Pressure Test	1279 Ashcroft Pressure Gage
		L-400 Maximator Liquid Pump
3.3	Hydraulic Impulse Pressure Test	PDCR 911 Druck Pressure Transducer
		451279 SSL 02B Ashcroft Pressure Gage
3.4	Repeated Remake Test	DLE 15-75 Maximator Air Booster Pump
		L-400 Maximator Liquid Pump
3.5	Tension Force Test	FI-90 Force Indicator
		31910 Load Cell
		DTM Dillon Tensile Tester
3.6	Vibration Stress / Endurance Test	42-05000W160S SC Hydraulic Engineering
		Booster Pump
		2100 Strain Gage Conditioner System
		THE Measurements Group
3.7	Intermix Assurance Test	DLE 15-75 Maximator Air Booster Pump
		L-400 Maximator Liquid Pump
3.8	Interchange Assurance Test	DLE 15-75 Maximator Air Booster Pump
		L-400 Maximator Liquid Pump
3.9	Gas Pressure Leak Test	HP 224 McDaniels Pressure Gage
		DLE 15-75 Maximator Air Booster Pump
3.10	Thermal Cycle, Thermal Shock Test	3210 Applied Test Systems Split Furnace
		XT16 Athena Temperature Controller
		MS-40 Veeco Helium Leak Detector
3.11	Vacuum Test	MS-40 Veeco Helium Leak Detector
3.12	Low Temperature (Cryogenic) Helium Leak Test	MS-40 Veeco Helium Leak Detector
		Type K TC Thermocouple

**TRADEMARKS:**

Griplok is a trademark of SSP Fittings Corp.

A-Lok, CPI are trademarks of Parker Hannifin Corporation

Swagelok is a trademark of Swagelok Co.

Gyrolok is a trademark of Hoke Incorporated

**SSP Instrumentation Document Number: ILGTR/22A**